



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Asaripallam Medical College Road, Post Office Upstair,

Asaripallam - 629201

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com



TC-10699

TEST REPORT

Doc.No: DWTL/PORM/7.8/01

Test Report No: 46648-46649	Report Issue Date : 18.05.2023
Invoice Details: 9964/ Dt.15.05.2023	

Customer Name & Address Contact No / Email.ID	: LHL CBSE School, Viswasapuram, Thovalai Post.
Sample Name	: Water
Sample Description	: RO Water - Drinking Purpose
Sample Submitted by	: Customer
Location & Date	: Viswasapuram
Quantity of sample Received	: 2 Litres
Sample Container	: PT Cane
Sample Condition on Receipt	: Good
Sample Received On	: 15.05.2023
Test Commenced on	: 15.05.2023
Test Completed on	: 18.05.2023
Environmental Condition	: 24.5 ⁰ C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
1	pH	IS 3025 Part 11-1983	-	6.64	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	IS 3025 Part 21-20009	mg/L	12	200	600
3	Total Alkalinity	IS 3025-Part 23-1986	mg/L	10	200	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	4	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	Less than 5	200	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO ₃ B	mg/L	Less than 2	45	45
7	Fluoride as F	APHA 23rd Edition 2017 - 4500- F-D	mg/L	0.2	1.0	1.5

[Signature]
Principal

LHL School

Note: LHL Nagar, Visuwasapuram,

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The Result apply to the sample as Received.

[Signature]
18/5/23

Authorised Signatory

B.Hari Govind - Assistant Executive Engineer

[Signature]
Chairman
LHL School

LHL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K.Dist.

Issue No./Date	01/01.10.2021	Amend. No/ Date	00/--	Page No
----------------	---------------	-----------------	-------	---------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Asaripallam Medical College Road, Post Office Upstair,

Asaripallam - 629201

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No: 46648-46649	Report Issue Date : 18.05.2023
-----------------------------	--------------------------------

Invoice Details: 9964/ Dt.15.05.2023

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
8	Appearance	Physical observation	--	Clear	-	-
9	Colour	APHA 23rd Edition 2017 4500 H+B	Hazen	Colourless	Agreeable	Agreeable
10	Odour	IS 3025 Part 5 : 1983	--	None	-	-
11	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
12	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	38	500	2000
13	Conductivity	APHA 23rd Edition 2017 - 2510 B	μS/cm	58	-	-
14	P - Alkalinity	IS 3025-Part 23-1983	mg/L	0	-	-
15	Calcium	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	6	75	200
16	Magnesium	APHA 23rd Edition 2017 - 3500 Mg B	mg/L	0	30	100
17	Sodium	APHA 23rd Edition 2017 - 3500 Na B	mg/L	8	-	-
18	Potassium	APHA 23rd Edition 2017 - 3500 K B	mg/L	2	-	-
19	Iron	APHA 23rd Edition 2017 - 3500 Fe B	mg/L	0.12	0.3	1
20	Manganese	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.1	0.3
21	Ammonia	APHA 17th Edition-1989- 4500 NH3C	mg/L	0.04	0.5	0.5
22	Nitrite as NO ₂	APHA 23rd Edition 2017 - 4500-NO2 B	mg/L	0.01	-	-
23	Total Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.05	-	-
24	Tidys	APHA 23rd Edition 2017 - 4500 O - B	mg/L	0.32	-	-
25	Residual Chlorine as RC	IS / APHA	mg/L	0	0.2	0.2
26	Faecal Coliform	IS / APHA	CFU / 100 ml	0	0	0

Remarks : The above water sample confirmed to IS 10500-2012. Drinking water specification with respect to above tested parameters.

.....End of the report.....

[Signature]

**Principal
LHL School**

LHL Nagar, Visuwasapuram,

Thovalai, Nagercoil, K.K. Dist.

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The Result apply to the sample as Received.

[Signature]

Authorised Signatory

B.Hari Govind - Assistant Executive Engineer

Issue No./Date	01/01.10.2021	Amend. No/ Date	00/--	Page No	2
----------------	---------------	-----------------	-------	---------	---

**Chairman
LHL School**

**LHL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.**



SANITARY CERTIFICATE

Ref. L. Dis. No. 4589/A4/2024

O/o. District Health Officer,
Health Unit District,
Nagercoil.

Dt:

THE TAMILNADU EDUCATIONAL RULES CHAPTER-III (Rule 24 & Appendix-3)

I hereby declare that I have caused to be inspect the building and premises of
.....L.H.L. School.....L.H.L. Nagar.....
.....Visuwasapuram.....
.....Thovalai..... Taluk, Kanyakumari District on 11.6.2024 and certify that the accommodation
provided for each and the several classes is sufficient for the maximum number of pupils taught therein and is
properly ventilated and lighted. That the building is maintained with substantial repairs and is neat and clean that
the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and that in
all other necessary aspects the sanitation is satisfactory.

This certificate valid upto 31.5.2025

Certificate is issued with the following conditions:

1. Establishing hand wash facilities at the entrance.
2. Toilets and Urinals must be kept hygienically clean and adequate water supply should be provided.
3. Environment and campus should be kept clean and neat and should be free from Dengue Aedes Larva.
4. Provide safe and protected drinking water.
5. First Aid box should be maintained with drug properly.
6. Tobacco prohibition board should be displayed as per COTPA 2003.

Dr. B. Subashini,
11.6.24


BLOCK HEALTH SUPERVISOR
GOVT. PRIMARY HEALTH CENTRE
CHENBAGARAMANPUTHOOR

Countersigned on the basis of the BHS inspection finding

District Health Officer,
Health Unit District,
Nagercoil.

7m
21/6/24

Principal



Chairman
LHL School

LHL Nagar Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.

LHL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.