



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126KKM24601

Organization Type : Educational Institutions

Name of the Organization : LHL SCHOOL


Address : LHL Nagar, Visuwasapuram, Thovalai, Nagercoil.

Issued Date : 09-02-2026

Expiry Date : 08-02-2027

I, **L HENDRY LOUIS** owner/manager of the **LHL SCHOOL** functioning as **Educational Institutions** located at **Veeramarthandanputhur** in **Kanniyakumari** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **09-02-2026** to **08-02-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
 - Our premises can accommodate **831** people/pupils and has **32** urinals and **26** toilets which is proportionate to the number of users as per government norms.
 - **2** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
 - The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
 - There is no potential mosquito breeding area on the premises.
 - The premises have adequate drinking water fountains on each floor of the premises.
 - The self-declared certificate is displayed prominently on the premises along with the protocol
- The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.


Principal

LHL School
LHL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.



Signature of the Owner/Manager

Chairman
LHL School

LHL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.



(அ) TN00126KKM24601 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை <https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.
(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.
Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN00126KKM24601 in the URL
<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Asaripallam Medical College Road, Post Office Upstair,

Asaripallam - 629201

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com



TC-10699

TEST REPORT

Doc.No: DWTL/PORM/7.8/01

Test Report No: 46648-46649	Report Issue Date : 18.05.2023
Invoice Details: 9964/ Dt.15.05.2023	

Customer Name & Address Contact No / Email.ID	: LHL CBSE School, Viswasapuram, Thovalai Post.
Sample Name	: Water
Sample Description	: RO Water -- Drinking Purpose
Sample Submitted by	: Customer
Location & Date	: Viswasapuram
Quantity of sample Received	: 2 Litres
Sample Container	: PT Cane
Sample Condition on Receipt	: Good
Sample Received On	: 15.05.2023
Test Commenced on	: 15.05.2023
Test Completed on	: 18.05.2023
Environmental Condition	: 24.5 ⁰ C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
1	pH	IS 3025 Part 11-1983	-	6.64	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	IS 3025 Part 21-20009	mg/L	12	200	600
3	Total Alkalinity	IS 3025-Part 23-1986	mg/L	10	200	600
4	Chloride as Cl	IS 3025-Part 32-1988	mg/L	4	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24-1986	mg/L	Less than 5	200	400
6	Nitrate as NO ₃	APHA 23rd Edition 2017- 4500 -NO ₃ B	mg/L	Less than 2	45	45
7	Fluoride as F	APHA 23rd Edition 2017 - 4500- F-D	mg/L	0.2	1.0	1.5

Prinith
Principal

LHL School

Note: HL Nagar, Visuwasapuram, K.K. Dist.

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The Result apply to the sample as Received.

B. Hari Govind
18/5/23

Authorised Signatory

B.Hari Govind - Assistant Executive Engineer

Chairman
Chairman
LHL School

HL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Asaripallam Medical College Road, Post Office Upstair,

Asaripallam - 629201

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No: 46648-46649 Report Issue Date : 18.05.2023

Invoice Details: 9964/ Dt.15.05.2023

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
8	Appearance	Physical observation	--	Clear	-	-
9	Colour	APHA 23rd Edition 2017 4500 H+B	Hazen	Colourless	Agreeable	Agreeable
10	Odour	IS 3025 Part 5 : 1983	--	None	-	-
11	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
12	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	38	500	2000
13	Conductivity	APHA 23rd Edition 2017 - 2510 B	µS/cm	58	-	-
14	P - Alkalinity	IS 3025-Part 23-1983	mg/L	0	-	-
15	Calcium	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	6	75	200
16	Magnesium	APHA 23rd Edition 2017- 3500 Mg B	mg/L	0	30	100
17	Sodium	APHA 23rd Edition 2017 - 3500 Na B	mg/L	8	-	-
18	Potassium	APHA 23rd Edition 2017 - 3500 K B	mg/L	2	-	-
19	Iron	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0.12	0.3	1
20	Manganese	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.1	0.3
21	Ammonia	APHA 17th Edition-1989- 4500 NH3C	mg/L	0.04	0.5	0.5
22	Nitrite as NO ₂	APHA 23rd Edition 2017- 4500-NO2 B	mg/L	0.01	-	-
23	Total Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.05	-	-
24	Tidys	APHA 23rd Edition 2017 - 4500 O - B	mg/L	0.32	-	-
25	Residual Chlorine as RC	IS / APHA	mg/L	0	0.2	0.2
26	Faecal Coliform	IS / APHA	CFU / 100 ml	0	0	0

Remarks : The above water sample confirmed to IS 10500-2012. Drinking water specification with respect to above tested parameters.

.....End of the report.....

Prinith
Principal

LHL School

LHL Nagar, Visuwasapuram,

Thovalai, Nagercoil, K.K. Dist.

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The Result apply to the sample as Received.

B.Hari Govind

Authorised Signatory

B.Hari Govind - Assistant Executive Engineer

Issue No./Date	01/01.10.2021	Amend. No/ Date	00/--	Page No	2
----------------	---------------	-----------------	-------	---------	---

Chairman
LHL School

LHL Nagar, Visuwasapuram,
Thovalai, Nagercoil, K.K. Dist.